



## GENERAL INSTRUCTIONS/EXAMPLE

School inspections shall be performed as specified in General Statute 115C-525(b). This form shall be completed and forwarded to the principal and superintendent of schools.

## EXAMPLE

### NORTH CAROLINA SCHOOL ELECTRICAL INSPECTION FORM (PUBLIC AND NON-PUBLIC SCHOOLS)

School Name <u>SLEEPY HALL HIGH SCHOOL</u>	Date <u>6/27/01</u>
Location <u>911 BATTLEGROUND AVE. GREENSBORO, N.C.</u>	Page <u>1</u> of <u>2</u>
Code <u>88-4734-1</u>	Inspector <u>J WATT</u>
Principal <u>JOHN MACNEIL</u>	Job No. <u>8849</u>

(1) Defect Code B and J under emergency exit fixtures indicates (B) broken or damaged (J) inoperative or not in proper working order. Remark 1-2 was made to specify the location and the nature of inoperation and breakage.

(2) Defect Code D indicates that the cover is missing or there are exposed live parts on the shop panelboard. No additional remarks were deemed necessary.

(3) "Table Saw" is an added item; Defect Code K indicates that special provisions or equipment is lacking; Remark 1-12 indicates a disconnect is to be provided

(4) Defect Code C indicates a deteriorated or worn cord; Remark 2-11 locates this cord to the refrigerator.

Key Remarks to Margin Reference (Example)	2	1	1-2	LIGHTING FIXTURES	EMERGENCY EXIT FIXTURES	SWMP SWITCHES	REE PTICLES	CONDUITS WIREWAYS	BOXES CABINETS	BRANCH FEEDER CIRCUITS	PANELBOARD SERVICE EQ	APPLIANCES	DISCONNECTS	CORDS	TABLESAW	
				1	2	3	4	5	6	7	8	9	10	11	12	13
Room or Location																
1	SHOP															
2	KITCHEN															
3																
4																
5																
6																
7																
8																
9																
10																
11																
12																
13																
14																
15																

Remarks:

1-2: SOUTH EXIT BATTERY DISCHARGED: LAMP BROKEN
1-12: PROVIDE DISCONNECT: 2-11 REFRIGERATOR

### DEFECT CODE

- A inadequately secured, supported or anchored
- B broken or damaged
- C deteriorated, worn, etc.
- D cover missing, exposed live parts
- E inadequate for application, environment, voltage, current
- F improper overcurrent protection, fuse, circuit breaker, etc.
- G improper identification
- H improper locks or accessibility
- J inoperative or not in proper working order
- K lacking special provisions or equipment
- L improper bonding or grounding
- M \_\_\_\_\_
- N \_\_\_\_\_

This is to certify that I have conducted the inspections as required by G.S. 115C-515(b) and to the best of my knowledge all items are properly noted.

\_\_\_\_\_  
Electrical Inspector

\_\_\_\_\_  
Date Completed