NC Department of Insurance Office of the State Fire Marshal - Engineering Division 1202 Mail Service Center, Raleigh, NC 27699-1202 919-661-5880

In-Use Type Receptacle Covers in Wet Locations

Code: 2008 Electrical Code Section: 406.8(B)

Date: July 1, 2009

Question:

Are in-use type receptacle covers (bubble covers) required for all receptacles in wet locations?

Answer:

All 15 and 20 ampere, 125- and 250- volt receptacles installed outdoors in wet locations are required to have an enclosure that is weatherproof whether or not the attachment plug cap is inserted.