NC Department of Insurance Office of the State Fire Marshal - Engineering Division 1202 Mail Service Center, Raleigh, NC 27699-1202 919-661-5880

Exit Enclosure Ventilation Systems

Code: 2012 Mechanical Code Date: September 1, 2011

Section: 601.3

Question:

Can an exit enclosure be heated and /or cooled by a ducted ventilation system serving another part of the building?

Answer:

No, Section 601.3 requires that exit enclosure ventilation systems be independent of other building ventilation systems.