

**INFORMAL CODE INTERPRETATION**

**NC Department of Insurance  
Office of the State Fire Marshal - Engineering Division  
1202 Mail Service Center, Raleigh, NC 27699-1202  
919-661-5880**

**Use of DASMA Technical Data Sheet 155h for Determining DP Ratings for Garage Doors**

**Code:** 2012 Residential Code

**Date:** July 3, 2012

**Section:** Table R301.2(4)  
Table R4502(b)

**Question:**

Can DASMA Technical Data Sheet 155h be used for determining alternate design pressures for garage doors?

**Answer:**

Yes. DASMA Technical Data Sheet 155h was inadvertently removed from footnote “a” of Table R301.2(4) and footnote “b” of Table R4502(b).

**Keywords:**

wind pressures, lateral loads