

## PROXIMATE PYROTECHNICS CHECKLIST (AHJ/Inspector)

- 1. Pyrotechnic walkthrough and demonstration:
  - a. Confirm venue management consent to pyrotechnics.
  - b. Verify pyrotechnic plot with actual site dimensions/adjustments.
- Type of devices verify indoor/proximate use & performance specifications (NFPA 1126: 5.1, 5.2, 5.3, 5.4).
- 3. Verify quantities, locations, and cueing of devices to be used.
- 4. Verify secure areas and methods for restricting unauthorized persons from entering.
- 5. Verify that all devices are securely fixed with proper audience separation:
  - a. Minimum 15 ft or 2X fallout radius (NFPA 1126: 6.4.1)
  - b. Concussion mortars a minimum 25 ft in secured area (NFPA 1126: 6.4.2)
  - c. Trajectory of comets/mines not over audience (NFPA 1126: 6.2.11)
  - d. Waterfall effect area free of flammable materials (NFPA 1126: 6.2.12)
  - e. Wire rocket effects properly secured and terminated (NFPA 1126: 6.2.9)
  - f. Airbursts over audience to be minimum height of 3 times the diameter of effect, and no sparks within 15 ft of floor (NFPA 1126: 6.2.14(1) & (2)
- 6. Check fire fighting equipment:
  - a. Minimum of 2 approved water fire extinguishers (NFPA 1126: 6.1.1.1)
  - b. Other firefighting equipment as needed/required (NFPA 1126: 6.1.1 & 6.1.1.2)
  - c. Existing on-site fire fighting equipment/systems
- 7. Pyrotechnic firing systems:
  - a. Verify operational/safety features and functions of systems (NFPA 1126: 6.3.2 & 6.3.3)
  - b. Verify operator & spotters have clear view of effects and communication with operator (NFPA 1126: 6.3.5)
- 8. Determine plan for HVAC /detectors adjustments & notification of demonstration.
- 9. Determine need for demonstration of representative effects.
- 10. Check plans for approved and secure on-site storage and preparation areas (NFPA 1126: 4.3.2 (I), 6.1.3 & 6.1.4):
  - a. Separation from heat/flame sparks (NFPA 1126: 3.3)
  - b. No smoking within 25 ft (signage) (NFPA 1126: 6.5.5)
  - c. Materials stored/handled neatly and orderly (NFPA 1126: 6.5.1)
- 11. Check plan for personal protective equipment for preparation and loading of pyrotechnics (NFPA 1126: 6.5.7).
- 12. Verify proper State Permit (see attached identification picture).
- 13. Verify all assistants have attended safety meeting; collect OSFM safety questionnaires.

